

May 26, 2009

**ADDENDUM NO. 1
FOR
HAPPY HOLLOW PARK & ZOO – PHASE 1 PARKING LOT PROJECT**

Notice is hereby given that the following revisions, additions, and/or deletions are hereby made a part of and incorporated into the plans and specifications for the Happy Hollow Park & Zoo – Phase 1 Parking Lot Project

PROJECT SPECIFICATIONS

1. SECTION 02720
PART 2-PRODUCTS
Under item A:
ADD: Trench Drain model style shall be “Marina” or approved equal with a cast iron finish.

PROJECT PLANS

1. SHEET C-18
PIPE BEDDING AND BACKFILL DETAIL
Under “Trench within New Paved Area” detail:
CHANGE: Type “C”, Class II Bedding per City Standard Specs 1301 shall be from bottom of subgrade to centerline of new pipe. Class 3 Aggregate Base Backfill with 95% relative compaction shall be above Type “C”, Class II Bedding to underneath new paving section.
2. SHEET L.3 and L.3.1
IRRIGATION MAINLINE:
The size of irrigation mainline is 2”.
3. SHEET A3.1
INTERIOR ELEVATIONS:
CHANGE: Elevation #1 call out to “Bldg D1 Eastside Restroom-Ticket”
CHANGE: Elevation #2 call out to “Bldg D1 Eastside Restroom-Women’s”
CHANGE: Elevation #3 call out to “Bldg D1 Eastside Restroom-Men’s”

INSTRUCTIONS

The bidder must sign this addendum in the space provided below and return one signed copy with the bid. Failure to return the signed copy with bid documents shall not relieve the bidder of the obligation to include this addendum to the bid proposal.


To: All Plan Holders for the Happy Hollow Park & Zoo – Phase 1 Parking Lot Project

Subject: **ADDENDUM NO. 1**

May 26, 2009

Page 2

APPROVED BY:



KATHERINE JENSEN

Division Manager

City Facilities Architectural Services Division

Department of Public Works

Bidder's Name _____

Signature and Title of Bidder

Date

KJ:GR:rc

Addendum No. 1_Happy Hollow Park & Zoo-Phase 1 Parking Lot